



October 4, 2023

Mr. David Zeck, CEFM
Facilities Manager
Franklin Township Board of Education
3228 Coles Mill Rd.
Franklinville, NJ 08322

RE: Indoor Air Quality Inspection Report – August 2023
Janvier Elementary School
Epic Project No. 23-2269

Dear Mr. Zeck:

Epic Environmental Services, LLC (Epic) was retained by the Franklin Township Board of Education (District) to perform indoor air quality inspections for five randomly selected areas at the Janvier Elementary School. One additional sample was taken specifically in the counselor’s office. The inspections consisted of visual observations and the collection of temperature and relative humidity data. Additionally, samples for airborne mold spores were collected in the inspection areas.

The visual inspections focused on signs of moisture, water intrusion, and visible mold growth.

Temperature and relative humidity data were compared to current New Jersey Indoor Air Quality and industry standards.

Epic Environmental performed the inspections on August 28/29, 2023.

Acceptable Temperature and Relative Humidity Criteria

Acceptable Indoor Temperature Range:	68° - 79° Fahrenheit
Ideal Relative Humidity Range:	30-60%

The following rooms/areas were inspected:

Room 36, Room 29, Room 18, Art Room, Room 10, Counselor’s Office

Observations, Comments, and Recommendations

Weather Conditions: Mostly Cloudy, 75° Fahrenheit, 78% Relative Humidity

Room 36

No visible mold was observed.
No evidence of recent water intrusion was observed.
Relative humidity was within the ideal range (56%). Temperature was within the acceptable range.
Airborne mold spore concentrations were near or below outside (background) concentrations.
No action required at this time.

Room 29

No visible mold was observed.
No evidence of recent water intrusion was observed.
Relative humidity was slightly elevated (67%). Temperature was within the acceptable range.
Airborne mold spore concentrations were near or below outside (background) concentrations.
No action required at this time.

Room 18

No visible mold was observed.
No evidence of recent water intrusion was observed.
Relative humidity was slightly elevated (67%). Temperature was within the acceptable range.
Airborne mold spore concentrations were near or below outside (background) concentrations.
No action required at this time.

Arm Room

No visible mold was observed.
No evidence of recent water intrusion was observed.
Relative humidity was within the ideal range (47%). Temperature was within the acceptable range.
Airborne mold spore concentrations were near or below outside (background) concentrations.
No action required at this time.

Room 10

No visible mold was observed.
No evidence of recent water intrusion was observed.
Relative humidity was within the ideal range (52%). Temperature was within the acceptable range.
Airborne mold spore concentrations were near or below outside (background) concentrations.
No action required at this time.

Counselor's Office

No visible mold was observed.
The carpeted floor was damp.
Relative humidity was slightly elevated (62%). Temperature was within the acceptable range.
Airborne Paecilomyces mold spore concentrations were slightly elevated.
Recommendations given to clean surfaces and dry the carpet were given.

Air Sample Results

Air samples were collected in each inspection area. Airborne Paecilomyces mold spore concentrations were slightly elevated in the counselor's office. Airborne mold spore concentrations were near or below background (outside) concentrations in all other areas.

See Sample Data Summary

Conclusions and General Recommendations

- Assure steps are taken to maintain a maximum relative humidity concentration of 60% during the summer months. This will reduce the overall probability of triggering mold activity.
- Ensure all carpets are fully dried after cleaning/wetting.

Please do not hesitate to contact me at 856-205-1077 should you have any questions.

An invoice for the completed project is enclosed.

Regards,



Tim Eberts
Senior Project Manager
Epic Environmental Services, LLC



James Eberts
President
Epic Environmental Services, LLC

Sample Data Summary Air Sampling

Air Samples August 28, 2023

Air Sample Location	Airborne Mold Concentrations (spores/m ³)	
	Total	Individual Mold Concentrations
Room 36	1160	Aspergillus/Penicillium 200 Basidiospores 880 Cladosporium 80
Room 29	960	Ascospores 80 Basidiospores 600 Cladosporium 200 Ganoderma 80
Room 18	500	Basidiospores 500
Art Room	1980	Basidiospores 1400 Cladosporium 500 Myxomycetes 80
Room 10	1480	Ascospores 80 Basidiospores 960 Cladosporium 400 Myxomycetes 40
Outside	9680	Ascospores 1600 Aspergillus/Penicillium 200 Basidiospores 6600 Cladosporium 1200 Ganoderma 80

Sample Data Summary Air Sampling

Air Samples August 29, 2023

Air Sample Location	Airborne Mold Concentrations (spores/m ³)	
	Total	Individual Mold Concentrations
Counselor Office	1080	Aspergillus/Penicillium 80 Basidiospores 80 Cladosporium 80 Pithomyces 40 Paecilomyces 800
Outside	8240	Ascospores 400 Aspergillus/Penicillium 1000 Basidiospores 5400 Cladosporium 960 Ganoderma 400 Pithomyces 80

- Individual molds listed in **green** indicate an individual airborne mold level NEAR or BELOW outside the (background) level.
- Individual molds listed in **purple** were not found in the background sample, but not considered evidence of a water/moisture issue or active mold growth.
- Individual molds listed in **red** indicate an individual airborne mold level ABOVE the outside (background) level, and may be an indicator of active mold growth in the area.

Airborne Paecilomyces mold spore concentrations were slightly elevated in the counselor's office.



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

EMSL Order: 372313514
Customer ID: EPIC62
Customer PO: 23-2269
Project ID:

Attention: James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
Fax: (856) 205-0413
Collected Date: 08/28/2023
Received Date: 08/28/2023
Analyzed Date: 09/05/2023

Project: Janvier ES IAQ

Test Report: Micro-5™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	372313514-0001			372313514-0002			372313514-0003		
Client Sample ID:	J-01			J-02			J-03		
Volume (L):	25			25			25		
Sample Location:	Outside			RM 36			RM 29		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	20	1600	16.5	-	-	-	1	80	8.3
Aspergillus/Penicillium	2	200	2.1	3	200	17.2	-	-	-
Basidiospores	83	6600	68.2	11	880	75.9	7	600	62.5
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	15	1200	12.4	1	80	6.9	2	200	20.8
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	1	80	0.8	-	-	-	1	80	8.3
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	121	9680	100	15	1160	100	11	960	100
Hyphal Fragment	1	80	-	1	80	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	80	-	-	80	-	-	80	-
Analyt. Sensitivity 300x	-	40*	-	-	40*	-	-	40*	-
Skin Fragments (1-4)	-	1	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Vincent Iuzzolino, M.S., Laboratory Director
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

Skin Fragment and Fibrous Particulate ratings are based on the percent of non-fungal material they represent: 1 (1-25%), 2 (26-50%), 3 (51-75%), or 4 (76-100%). Background ratings are based on the total area covered by non-fungal particles: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-99%), or 5 (100%; overloaded, prohibiting accurate detection and quantification). High levels of background will obscure spores and other particulates, leading to underestimation. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "*" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA LAP, LLC-EMLAP Accredited #100194

Initial report from: 09/05/2023 12:31 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077

Tel/Fax: (800) 220-3675 / (856) 786-0262

http://www.EMSL.com / cinnmicrolab@emsl.com

EMSL Order: 372313514

Customer ID: EPIC62

Customer PO: 23-2269

Project ID:

Attention: James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
Fax: (856) 205-0413
Collected Date: 08/28/2023
Received Date: 08/28/2023
Analyzed Date: 09/05/2023

Project: Janvier ES IAQ

Test Report: Micro-5™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	372313514-0004			372313514-0005			372313514-0006		
Client Sample ID:	J-04			J-05			J-06		
Volume (L):	25			25			25		
Sample Location:	RM 18			Art RM			RM 10		
Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	1	80	5.4
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	6	500	100	18	1400	70.7	12	960	64.9
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	6	500	25.3	5	400	27
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	1*	40*	2.7
Myxomycetes++	-	-	-	1	80	4	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	6	500	100	25	1980	100	19	1480	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	80	-	-	80	-	-	80	-
Analyt. Sensitivity 300x	-	40*	-	-	40*	-	-	40*	-
Skin Fragments (1-4)	-	2	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Vincent Iuzzolino, M.S., Laboratory Director
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

Skin Fragment and Fibrous Particulate ratings are based on the percent of non-fungal material they represent: 1 (1-25%), 2 (26-50%), 3 (51-75%), or 4 (76-100%). Background ratings are based on the total area covered by non-fungal particles: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-99%), or 5 (100%; overloaded, prohibiting accurate detection and quantification). High levels of background will obscure spores and other particulates, leading to underestimation. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA LAP, LLC-EMLAP Accredited #100194

Initial report from: 09/05/2023 12:31 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Microbiology Chain of Custody Form

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
EMAIL: c@emsl.com

372313514

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information	Customer ID:				Billing Information	Billing ID:			
	Company Name: Epic Environmental Services, LLC					Company Name: Epic Environmental Services, LLC			
	Contact Name: James Eberts					Billing Contact: James Eberts			
	Street Address: 80 Fork Bridge Road					Street Address: 80 Fork Bridge Road			
	City, State, Zip: Pittsgrove NJ 08318		Country: US			City, State, Zip: Pittsgrove NJ 08318		Country: US	
	Phone: 856-205-1077					Phone: 856-205-1077			
	Email(s) for Report: jeberts@epicenviro.com					Email(s) for Invoice:			

Project Information				
Project Name/No: <u>Janvier ES 1AQ</u>			Purchase Order: <u>ZB-2269</u>	
EMSL LIMS Project ID: (if applicable, EMSL will provide)		State Samples Collected: <u>NJ</u>	Zip Code Samples Collected:	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-taxable)
Sampled By Name: <u>Timothy Eberts</u>		Sampled By Signature: <u>[Signature]</u>		No. of Samples in Shipment: <u>6</u>
Sterile, Sodium Thiosulfate Preserved Bottle Used: <input type="checkbox"/> Biocide Used in Source (specify)				
Public Water Supply Samples: <input checked="" type="checkbox"/> Note: All results may automatically be reported to DOH if required by State.				
Turn-Around-Time (TAT) <small>Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only, samples must be submitted by 11:30am.</small>				
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 32* Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input checked="" type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week

MICROBIOLOGY TEST CODES			
M001 Air-O-Cell	M174 MoldSnap	M012 Pseudomonas aeruginosa (PIA***)	M115 Sewage Screen - Water (PIA***)
M030 Micro 5	M032 Allergenco-D	M024 Pseudomonas aeruginosa (MFT*)	M116 Sewage Screen - Water (MPN**)
M041 Fungal Direct Examination		M015 Heterotrophic Plate Count	M117 Sewage Screen - Swab (PIA***)
M169 Pollen ID & Enumeration		M017 Total Coliform & E. Coli (Colilert PIA***)	M013 Sewage Screen - Swab (MFT*)
M280 Dust Characterization Level-1		M018 Total Coliform & E. Coli (MFT*)	M730 Methicillin-resistant Staph. aureus (MRSA)
M281 Dust Characterization Level-2		M114 Total Coliform & E. Coli Enumeration (Colilert MPN**)	M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration
M005 Viable Fungi-Air Samples (Genus ID & Count)		M019 Fecal Coliform (MFT*)	M014 Endotoxin Analysis
M006 Viable Fungi-Air Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)		M020 Fecal Streptococcus (MFT*)	M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite)
M007 Culturable Fungi-Surface Samples (Genus ID & Count)		M029 Enterococci (MFT*)	M095 Bacteroides
M008 Culturable Fungi-Surface Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)		M129 Enterococci (Enterolert PIA***)	Other - See Analytical Price Guide for Test Code
M009 Bacteria Culture Gram Stain & Count		M180 Real Time qPCR-ERMI 36 Panel	Legionella Analysis Please use EMSL Legionella COC
M010 Bacteria Count & ID - 3 Most Prominent		M025 Sewage Screen - Water (MFT*)	
M011 Bacteria Count & ID - 5 Most Prominent		*MFT= Membrane Filtration Technique	
		**MPN = Most Probable Number	
		***PIA = Presence/Absence	

Sample #	Sample Location/Description	Sample Type (Matrix)	Potable / Non-Potable (Only for Water)	Test Code	Volume/Area	Date / Time Collected	Temperature (Lab Use Only)
Example: Sample 1	Kitchen	Water	Potable	M017	1,000 ml	1/1/2021 3:30pm	
J-01	OUTSIDE	AIR		M030	25L	8/28/23 1007	
J-02	RM 36					1019	
J-03	RM 29					1026	
J-04	RM 18					1032	
J-05	AIR RM					1035	
J-06	RM 10					1045	

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: <u>[Signature]</u>	Date/Time: <u>8/28/23 1400</u>	Received by: <u>[Signature] DB</u>	Date/Time: <u>8/28/23 1300</u>
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document - COC-34 Micro R13 03/02/2021 AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

EMSL Order: 372313535
Customer ID: EPIC62
Customer PO: 23-2269
Project ID:

Attention: James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
Fax: (856) 205-0413
Collected Date: 08/24/2023
Received Date: 08/29/2023
Analyzed Date: 09/06/2023

Project: Janvier Counselor Rm IAQ

Test Report: Micro-5(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	372313535-0001			372313535-0002			
Client Sample ID:	J-01			J-02			
Volume (L):	25			25			
Sample Location:	Outside			Counselor Office			
Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	
Alternaria (Ulocladium)	-	-	-	-	-	-	-
Ascospores	5	400	4.9	-	-	-	-
Aspergillus/Penicillium	13	1000	12.1	1	80	7.4	-
Basidiospores	68	5400	65.5	1	80	7.4	-
Bipolaris++	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-
Cladosporium	12	960	11.7	1	80	7.4	-
Curvularia	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-
Ganoderma	5	400	4.9	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-
Pithomyces++	1	80	1	1*	40*	3.7	-
Rust	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-
Stachybotrys/Memmoniella	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-
Paecilomyces++	-	-	-	10	800	74.1	-
Total Fungi	104	8240	100	14	1080	100	
Hyphal Fragment	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-
Pollen	-	-	-	2*	80*	-	-
Analyt. Sensitivity 600x	-	80	-	-	80	-	-
Analyt. Sensitivity 300x	-	40*	-	-	40*	-	-
Skin Fragments (1-4)	-	1	-	-	2	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	2	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Vincent Iuzzolino, M.S., Laboratory Director
or other Approved Signatory

Skin Fragment and Fibrous Particulate ratings are based on the percent of non-fungal material they represent: 1 (1-25%), 2 (26-50%), 3 (51-75%), or 4 (76-100%). Background ratings are based on the total area covered by non-fungal particles: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-99%), or 5 (100%, overloaded, prohibiting accurate detection and quantification). High levels of background will obscure spores and other particulates, leading to underestimation. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA LAP, LLC-EMLAP Accredited #100194

Initial report from: 09/06/2023 03:14 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

372313535

Environmental Microbiology Chain of Custody

Westmont, NJ
 107 Haddon Avenue
 Westmont, NJ 08108
 PHONE: (856) 858-4800
 FAX: (856) 858-4960



EMSL Order Number (Lab Use Only):

[Empty box for EMSL Order Number]

Company: Epic Environmental Services, LLC		EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments** <i>Third Party Billing requires written authorization from third party</i>			
Street: 1930 Brown Road					
City/State/Zip: Newfield, NJ 08344					
Report To (Name): James Eberts		Fax: 856-205-0413			
Telephone: 856-205-1077		Email Address: jeberts@epicenviro.com			
Project Name/Number: <u>Javier Counselor Rm 1A2</u>					
Please Provide Results: Email		Purchase Order: <u>23-2269</u>	State Samples Taken: NJ		
Turnaround Time (TAT) Options* - Please Check					
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour		
<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input checked="" type="checkbox"/> 1 Week	<input type="checkbox"/> 2 Week		
<small>*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements</small>					
Non Culturable Air Samples (Spore Traps)					
<ul style="list-style-type: none"> • M001 Air-O-Cell • M049 BioSIS • M030 Micro 5 	<ul style="list-style-type: none"> • M173 Allegro M2 • M003 Burkard • M174 MoldSnap 	<ul style="list-style-type: none"> • M004 Allergenco • M043 Cyclex • M176 Relle Smart 	<ul style="list-style-type: none"> • M032 Allergenco-D • M002 Cyclex-d • M130 Via-Cell • M172 Versa Trap 		
Other Microbiology Test Codes					
<ul style="list-style-type: none"> • M041 Fungal Direct Examination • M005 Viable Fungi ID and Count • M006 Viable Fungi ID and Count (Speciation) • M007 Culturable Fungi • M008 Culturable Fungi (Speciation) • M009 Gram Stain Culturable Bacteria • M010 Bacterial Count and ID - 3 Most Prominent • M011 Bacterial Count and ID - 5 Most Prominent • M013 Sewage Contamination in Buildings 	<ul style="list-style-type: none"> • M014 Endotoxin Analysis • M015 Heterotrophic Plate Count • M100 Real Time Q-PCR-ERMI 36 Panel • M018 Total Coliform (Membrane Filtration) • M020 Fecal Streptococcus (Membrane Filtration) • M210-215 Legionella Detection • M026 Recreational Water Screen • M027 Mycotoxin Analysis 	<ul style="list-style-type: none"> • M029 Enterococci • M019 Fecal Coliform • M133 MRSA Analysis • M028 Cryptococcus neoformans Detection • M120 Histoplasma capsulatum Detection • M033-39 Allergen Testing (Cat, Dog, Cockroach, Dust Mites) • M044 Group Allergen • Other See Analytical Price Guide 			
Preservation Method (Water):					
Name of Sampler: <u>Timothy Eberts</u>		Signature of Sampler:			
Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
J-01	Outside	AIR	M030	25L	8/29/23 0742
J-02	Counselor office	↓	↓	↓	↓ 0758
Client Sample # (s): <u>J-01 - J-02</u>		Total # of Samples:		<u>2</u>	
Relinquished (Client):		Date: <u>8/29/23 1000</u>		Time:	
Received (Client): <u>Shawn DB</u>		Date: <u>8/29/23</u>		Time: <u>120p</u>	
Comments/Special Instructions:					

RECEIVED
 ENVIRONMENTAL
 GINNAMON, N.J.
 2023 AUG 29 PM 11:10



AIHA Laboratory Accreditation Programs, LLC
acknowledges that
EMSL Analytical, Inc.
200 Route 130 North Cinnaminson, NJ 08077
Laboratory ID: LAP-100194

along with all premises from which key activities are performed, as listed above, has fulfilled the requirements of the AIHA Laboratory Accreditation Programs (AIHA LAP), LLC accreditation to the ISO/IEC 17025:2017 international standard, General Requirements for the Competence of Testing and Calibration Laboratories in the following:

LABORATORY ACCREDITATION PROGRAMS

<input checked="" type="checkbox"/>	INDUSTRIAL HYGIENE	Accreditation Expires: January 01, 2025
<input checked="" type="checkbox"/>	ENVIRONMENTAL LEAD	Accreditation Expires: January 01, 2025
<input checked="" type="checkbox"/>	ENVIRONMENTAL MICROBIOLOGY	Accreditation Expires: January 01, 2025
<input type="checkbox"/>	FOOD	Accreditation Expires:
<input type="checkbox"/>	UNIQUE SCOPES	Accreditation Expires:

Specific Field(s) of Testing (FoT)/Method(s) within each Accreditation Program for which the above named laboratory maintains accreditation is outlined on the attached Scope of Accreditation. Continued accreditation is contingent upon successful on-going compliance with ISO/IEC 17025:2017 and AIHA LAP, LLC requirements. This certificate is not valid without the attached Scope of Accreditation. Please review the AIHA LAP, LLC website (www.aihaaccreditedlabs.org) for the most current Scope.

Cheryl O Morton
Managing Director, AIHA Laboratory Accreditation Programs, LLC